

# Driver LST400 HART Level Transmitter LST400 Ultrasonic Level Transmitter

## Contents

1	Device - Revision Record - What is new? .....	2
1.1	Hardware ID: 1A9C .....	2
1.2	Software/Firmware.....	2
1.3	Device (latest SW compatibility status).....	2
1.4	Supported devices.....	2
1.5	Cyber Security info .....	2
1.5.1	ABB recommendation .....	2
1.6	Licensing.....	2
2	EDD (Electronic Device Description) .....	3
2.1	EDD Version record - What is new?.....	3
2.2	Supported Languages .....	3
2.3	Requirements.....	3
2.4	Remove / import and configuration .....	3
2.5	Known problems and limitations.....	3
2.6	Getting help / further information .....	3
2.7	How to get the latest information & software?.....	3
	Contacts.....	4

\*) DTM500 Bundle Supplement Info is available on the data medium \documentation or latest on [www.abb.com/fieldbus](http://www.abb.com/fieldbus).  
Enter here in the search field following No. "3KXD801500R3901".

# 1 Device - Revision Record - What is new?

## 1.1 Hardware ID: 1A9C

Released Revision	Released Date	Remarks
15.14.15	Jan 2017	First release

## 1.2 Software/Firmware

Released Revision	Released Date	Remarks
05.43	Jul 2016	First release

## 1.3 Device (latest SW compatibility status)

Released Revision	Released Date	Remarks
01	June 2017	First release

## 1.4 Supported devices

LST400 HART Ultrasonic with HW Version 15.14.15 (Main Board) and 10.11.11 (LCD Board), SW Version 05.43.00 and Device revision 01 .

## 1.5 Cyber Security info

### 1.5.1 ABB recommendation

A virus scanner shall be used on all PCs/Notebooks. McAfee VirusScan® Enterprise has been tested and qualified for this purpose.

## 1.6 Licensing

The "General terms of license for computer soft-ware utilization" are valid, which can be found by searching on [abb.com](http://abb.com)

## 2 EDD (Electronic Device Description)

### 2.1 EDD Version record - What is new?

Released Version (Dev Rev)	Released Date	Remarks
01 01	May 2020	First release

### 2.2 Supported Languages

The device EDD supports English

### 2.3 Requirements

Compatible to IEC61804-3, -4, -5 Electronic De-vice Description Language (EDDL)

### 2.4 Remove / import and configuration

Start your EDD Host application and follow the instructions.

### 2.5 Known problems and limitations

None

### 2.6 Getting help / further information

Help concerning the integration of the driver in the EDD Host application can be found in the respective documentation of the frame application.

Use mouse over for field hints and tooltips.

### 2.7 How to get the latest information & software?

The latest device driver Supplement Info & software (driver) is available on [www.abb.com/measurement](http://www.abb.com/measurement)

## Contacts

—

ABB Limited  
Measurement & Analytics  
Howard Road, St. Neots  
Cambridgeshire, PE19 8EU  
UK  
Tel: +44 (0) 870 600 6122  
Fax: +44 (0)1480 213 339  
Email: [enquiries.mp.uk@gb.abb.com](mailto:enquiries.mp.uk@gb.abb.com)

ABB Inc.  
Measurement & Analytics  
125 E. County Line Road  
Warminster, PA 18974  
USA  
Tel: +1 215 674 6000  
Fax: +1 215 674 7183  
[www.abb.com/measurement](http://www.abb.com/measurement)

ABB Automation Products GmbH  
Measurement & Analytics  
Schillerstr. 72  
32425 Minden  
Germany  
Tel: +49 571 830-0  
Fax: +49 571 830-1806  
Email: [www.abb.com/contact](http://www.abb.com/contact)

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail.  
ABB does not accept any responsibility whatsoever for potential errors or possible lack of information in this document. We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB.

Copyright© 2020 ABB  
All rights reserved