



中国国家强制性产品认证证书

证书编号：2014010304744408

委托人名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产者（制造商）名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

软起动器

PSTX210-600-70, PSTX250-600-70, PSTX300-600-70, PSTX370-600-70,
PSTX210-690-70, PSTX250-690-70, PSTX300-690-70, PSTX370-690-70: 详细参数及型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2019年08月09日 有效期至：2024年08月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2014年12月24日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：

陆梅



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010304744408

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

soft starter

PSTX210-600-70,PSTX250-600-70, PSTX300-600-70, PSTX370-600-70, PSTX210-690-70,
PSTX250-690-70, PSTX300-690-70,PSTX370-690-70: See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.09,2019

Valid until: Aug.09,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.24,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2014010304744408

纸 号: 2371678

PSTX210-600-70, PSTX250-600-70,
 PSTX300-600-70, PSTX370-600-70,
 PSTX210-690-70, PSTX250-690-70,
 PSTX300-690-70, PSTX370-690-70
 PSTX210-600-70, PSTX250-600-70,
 PSTX300-600-70, PSTX370-600-70

Ui: 600V; Ue: 208-550V AC ;

I_{th}= I_e: 210A (PSTX210-600-70) ; 250A (PSTX250-600-70)
 300A (PSTX300-600-70) ; 370A (PSTX370-600-70)

PSTX210-690-70, PSTX250-690-70,
 PSTX300-690-70, PSTX370-690-70

Ui: 690V; Ue: 208-690V AC ;

I_{th}= I_e: 210A (PSTX210-690-70) ; 250A (PSTX250-690-70) ;
 300A (PSTX300-690-70) ; 370A (PSTX370-690-70)

Pe:

产品型号	额定工作 电 流 I _e (A)	额定功率(kW)			
		220-230V	380-400V	500V	690V
PSTX210-600-70	210	59	110	132	-
PSTX250-600-70	250	75	132	160	-
PSTX300-600-70	300	90	160	200	-
PSTX370-600-70	370	110	200	257	-
PSTX210-690-70	210	59	110	132	184
PSTX250-690-70	250	75	132	160	220
PSTX300-690-70	300	90	160	200	257
PSTX370-690-70	370	110	200	257	355

AC-53a; 3P

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2014010304744408

纸 号：2371678

型号解释：

$\frac{PSTX}{1} \frac{***}{2} - \frac{***}{3} - \frac{70}{4}$

1 = Softstarter, name of series

2 = Current rating, In line Ie.: 210=210A, 370=370A

3 = Operational voltage, Ue: 600 = 208-550V AC, 690 = 208-690V AC

4 = Control supply voltage, Us: 70 = 100 - 250V AC

注：此附录与证书同时使用时有效。



主 任：

陆 杨



中国质量认证中心