



# 中国国家强制性产品认证证书

证书编号：2006010304208085

委托人名称、地址

ABB AB, Control Products  
SE-721 61 Vasteras Sweden

生产者（制造商）名称、地址

ABB AB, Control Products  
SE-721 61 Vasteras Sweden

生产企业名称、地址

ABB 新会低压开关有限公司  
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

软起动器

PSR3-600-70, PSR6-600-70, PSR9-600-70, PSR12-600-70, PSR16-600-70, PSRC3-600-70, PSRC6-600-70,  
PSRC9-600-70, PSRC12-600-70, PSRC16-600-70, PSR3-600-11, PSR6-600-11, PSR9-600-11, PSR12-600-11,  
PSR16-600-11, PSRC3-600-11, PSRC6-600-11, PSRC9-600-11, PSRC12-600-11, PSRC16-600-11,  
PSRC3-600-70-1, PSRC6-600-70-1, PSRC9-600-70-1, PSRC12-600-70-1, PSRC16-600-70-1; 详细参数及型号  
解释见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2019年03月25日 有效期至：2024年03月25日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2006年11月02日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：陆梅



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2006010304208085

## NAME AND ADDRESS OF THE APPLICANT

ABB AB,Control Products  
SE-721 61 Vasteras Sweden

## NAME AND ADDRESS OF THE MANUFACTURER

ABB AB,Control Products  
SE-721 61 Vasteras Sweden

## NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

soft starter

PSR3-600-70, PSR6-600-70, PSR9-600-70, PSR12-600-70, PSR16-600-70, PSRC3-600-70, PSRC6-600-70, PSRC9-600-70, PSRC12-600-70, PSRC16-600-70, PSR3-600-11, PSR6-600-11, PSR9-600-11, PSR12-600-11, PSR16-600-11, PSRC3-600-11, PSRC6-600-11, PSRC9-600-11, PSRC12-600-11, PSRC16-600-11, PSRC3-600-70-1, PSRC6-600-70-1, PSRC9-600-70-1, PSRC12-600-70-1, PSRC16-600-70-1; See the attachment for detailed parameters and explanation

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.25,2019

Valid until: Mar.25,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Nov.02,2006

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2006010304208085

纸 号: 2241803

详细参数:

PSR3-600-70, PSR6-600-70, PSR9-600-70, PSR12-600-70, PSR16-600-70, PSRC3-600-70, PSRC6-600-70, PSRC9-600-70, PSRC12-600-70, PSRC16-600-70, PSR3-600-11, PSR6-600-11, PSR9-600-11, PSR12-600-11, PSR16-600-11, PSRC3-600-11, PSRC6-600-11, PSRC9-600-11, PSRC12-600-11, PSRC16-600-11, PSRC3-600-70-1, PSRC6-600-70-1, PSRC9-600-70-1, PSRC12-600-70-1, PSRC16-600-70-1

额定绝缘电压(Ui): 600V;

约定发热电流(Ith):

PSR3-600-70, PSR3-600-11, PSRC3-600-11, PSRC3-600-70, PSRC3-600-70-1: 3.9A,  
PSR6-600-70, PSR6-600-11, PSRC6-600-11, PSRC6-600-70, PSRC6-600-70-1: 6.8A,  
PSR9-600-70, PSR9-600-11, PSRC9-600-11, PSRC9-600-70, PSRC9-600-70-1 : 9A,  
PSR12-600-70, PSR12-600-11, PSRC12-600-11, PSRC12-600-70, PSRC12-600-70-1: 12A,  
PSR16-600-70, PSR16-600-11, PSRC16-600-11, PSRC16-600-70, PSRC16-600-70-1: 16A;

额定工作电压(Ue): AC208~600V;

额定工作电流(Ie): 3.9A, 6.8A, 9A, 12A, 16A;

额定功率(Pe):

PSR3-600-70, PSR3-600-11, PSRC3-600-11, PSRC3-600-70, PSRC3-600-70-1:  
230VAC/0.75kW, 400VAC/1.5kW, 500VAC/2.2kW;  
PSR6-600-70, PSR6-600-11, PSRC6-600-11, PSRC6-600-70, PSRC6-600-70-1:  
230VAC/1.5kW, 400VAC/3kW, 500VAC/4kW;  
PSR9-600-70, PSR9-600-11, PSRC9-600-11, PSRC9-600-70, PSRC9-600-70-1 :  
230VAC/2.2kW, 400VAC/4kW, 500VAC/4kW;  
PSR12-600-70, PSR12-600-11, PSRC12-600-11, PSRC12-600-70, PSRC12-600-70-1:  
230VAC/3kW, 400VAC/5.5kW, 500VAC/5.5kW;  
PSR16-600-70, PSR16-600-11, PSRC16-600-11, PSRC16-600-70, PSRC16-600-70-1:  
230VAC/4kW, 400VAC/7.5kW, 500VAC/7.5kW;

使用类别: AC-53a; 极数: 3P; 外壳防护等级: IP20

注: 此附录与证书同时使用时有效。



主任:

陆梅



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2006010304208085

纸 号: 2241803

型号的解释:

(Explanation of model/ type)

PSR 3-600-70-1

1 2 3 4 5

1 = Product family name (Soft starter), it can be PSR or PSRC;  
(产品系列 (软起动器), 可以是 PSR 或 PSRC)

2 = Rated motor current (in line), it can be 3, 6, 9, 12, 16;  
(额定电机电流 (外接法), 可以是 3,6,9,12,16)

3 = Rated main voltage, it can be 600;  
(额定主回路电压, 是 600)

4 = Supply voltage, Us, it can be 70, 11;  
(控制回路电源电压 Us, 可以是 70 或 11)  
70=100-240 V AC, 11=24V AC/DC;

5 = Design code, it can be 1 or blank;  
(设计代码, 可以是 1 或 空白)

1 = Customer specific software not related to safety (optional, only PSRC).  
(特定客户软件版本, 与安全无关(PSRC 系列可选))

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



## 中国质量认证中心